

Second Copy — Owner's Copy  
Third Copy — Driller's Copy 31/3E/33/P

(1) OWNER: Name Port Susan Terrace Assoc. Address \_\_\_\_\_

(2) LOCATION OF WELL: County Gout lot 1 - 1/4 1/4 Sec. 33 T 31 N, R 3E W.M.

Bearing and distance from section or subdivision corner 2150' E & 200' N of SW cor of Sec 33

(3) **PROPOSED USE:** Domestic ☐ Industrial ☐ Municipal ☒  
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) . . . . .

New well	<input checked="" type="checkbox"/>	Method: Dug	<input type="checkbox"/>	Bored	<input type="checkbox"/>
Deepened	<input type="checkbox"/>	Cable	<input checked="" type="checkbox"/>	Driven	<input type="checkbox"/>
Reconditioned	<input type="checkbox"/>	Rotary	<input type="checkbox"/>	Jetted	<input type="checkbox"/>

(5) **DIMENSIONS:** Diameter of well ..... inches.  
 Drilled ..... ft. Depth of completed well ..... ft.

**(6) CONSTRUCTION DETAILS:**

**Casing installed:** 6" Diam. from 0 ft. to 216 ft.  
 Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Welded ☒ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used.....  
 SIZE of perforations ..... in. by ..... in.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐

Manufacturer's Name Johnson  
Type 304 Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**Surface seal:** Yes ☒ No ☐ To what depth? 20 ft  
Material used in seal Mud  
Did any strata contain unusable water? Yes ☐ No ☒  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name Meyers  
Type: Submersible HP 3

(8) **WATER LEVELS:** Land-surface elevation above mean sea level... 180 ft.  
 Static level 180 ft. below top of well Date.....  
 Artesian pressure ..... lbs. per square inch Date.....  
 Artesian water is controlled by..... (Cap. valve, etc.)

**(9) WELL TESTS:** Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? .....

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"
"	"	"	"

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
.....	.....	.....	.....	.....	.....
.....	.....	.....	.....	.....	.....

Date of testing 10 1966  
 Baller test 20 gal./min. with 4 ft. drawdown after 4 hr  
 Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
 Temperature of water 50 Was a chemical analysis made? Yes ☒ No ☐

**(10) WELL LOG:**

**Formation:** Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
hardpan	0	45
Clayey sand	45	175
Silty sand	175	200
fine sand	200	221

Work started Aug 3, 1966 Completed Aug 10, 1966

**WELL DRILLER'S STATEMENT:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kunkle/Well Drilling  
(Person, firm, or corporation) (Type or print)

Address. 797 N Smith Rd Camarillo Wa 93010

[Signed] A. G. Kautsch  
(Well Driller)

License No. 247 Date Feb-10, 1977